



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jul 26, 2023

Inspection Result: PASSED

Permit Number: PRMH221659

Issuance Date: Nov 02, 2022

Property Address: 42375 RIVER DRUM TRL, UNITB, ROUTT, CO 80487;

Applicant: COLORADO PLUMBING & HEATING

Contractor: COLORADO PLUMBING & HEATING P.O. BOX 775302 STEAMBOAT
SPGS, CO 80477 (970) 846-6478

To construct: Radiant Heat System with Boiler and Gas Piping.

On this day we have inspected your construction for **Approval for Gas Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: New boiler has been installed and vented correctly and is ready to operate. Green tag issued.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347