



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jul 31, 2023

Inspection Result: PASSED

Permit Number: PRPL230755

Issuance Date: Jul 09, 2023

Property Address: 28305 YELLOW JACKET DR, ROUTT, CO 80467;

Applicant: Stephen Jones

Contractor: J & I Plumbing and Heating Services LLC 1664 Yampa Ave, Thr 26 Craig, CO 81625

To construct: Building Permit #PRPF221773 -- Factory built 572 sq ft home on 20 acre parcel

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: DWV and waterline connections made. Waterlines are live and DWV flow test performed. Hammer arrester needs to be installed on dishwasher supply, note made in conditions of building permit. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us
(970) 870-5331