



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Aug 07, 2023

Inspection Result: PASSED

Permit Number: PRAD221473

Issuance Date: Nov 30, 2022

Property Address: 27315 HOME RANCH RD, UNITA, ROUTT, CO 80428;

Applicant: SNAKE RIVER CONSTRUCTION

Contractor: SNAKE RIVER CONSTRUCTION PO BOX 773504 Steamboat Springs, CO
80477 (970) 846-2301

To construct: Construction of the 'Fitness Building' portion of the Lodge

On this day we have inspected your construction for **Foundation Drain Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Perforated drain pipe has been installed and bedded correctly with cleanouts. Correct gravel and fabric cover installed, R15 fiber drain board installed on exterior. Approved to backfill.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347