



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Aug 08, 2023

Inspection Result: PASSED

Permit Number: PRPL230871

Issuance Date: Jul 25, 2023

Property Address: 45370 COUNTY ROAD 52, ROUTT, CO 80487;

Applicant: TBH PLUMBING & HEATING

Contractor: TBH PLUMBING & HEATING P.O. BOX 882183 STEAMBOAT SPGS,, CO
80488 (970) 846-4702

To construct: Install water heater, 3 compartment sink, hand sink, and floor sink

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: DWV and water lines for kitchen sinks have been installed, supported and protected correctly. Pressure tests good for 15 minutes. Cabins will not be used in winter and drained. Final approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347