



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Aug 17, 2023

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRMH230943

**Issuance Date:** Aug 03, 2023

**Property Address:** 27315 HOME RANCH RD, UNITA, ROUTT, CO 80428;

**Applicant:** ACTION MECHANICAL INC.

**Contractor:** ACTION MECHANICAL INC. P.O. BOX 698 CLARK, CO 80428 (970) 819-1174

**To construct:** in-floor htg

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Heat tubing in basement slab is installed and fastened correctly over 2" spray foam. Pressure test good at 100 psi for 15 minutes. Approved to pour.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347