



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 05, 2023

Inspection Result: PARTIAL PASS

Permit Number: PRPL230942

Issuance Date: Aug 03, 2023

Property Address: 27315 HOME RANCH RD, UNITA, ROUTT, CO 80428;

Applicant: ACTION MECHANICAL INC.

Contractor: ACTION MECHANICAL INC. P.O. BOX 698 CLARK, CO 80428 (970) 819-1174

To construct: complete plbg system

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: DWV lines for downstairs bathroom and mechanical room have been installed and bedded correctly per approved plans. Pressure test good at 5 psi for 15 minutes. Approved to backfill.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347