



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 25, 2023

Inspection Result: PASSED

Permit Number: PRPF230984

Issuance Date: Sep 05, 2023

Property Address: 18195 STATE HIGHWAY 131, ROUTT, CO 80483;

Applicant: Elizabeth Herbert

Contractor: Amplify Architecture PO Box 774121 Steamboat Springs, CO 80477 (970) 879-7929

To construct: Set Modular on a crawl space foundation.

FOUNDATION ONLY pending receipt of State Approved Plans and Installation Authorization Form. 8.24.23. MMF

On this day we have inspected your construction for **Foundation Drain Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Foundation drain complete, gravel and wrap, ok to close up and fill

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371