



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Sep 26, 2023

**Inspection Result:** PARTIAL PASS

**Permit Number:** PREL230829

**Issuance Date:**

**Property Address:** 27875 US HIGHWAY 40, UNITB, ROUTT, CO 80487;

**Applicant:** James Burgess

**Contractor:**

**To construct:** New service for irrigation pump.

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** 682 15 of the NEC requires GFI protection for outlets near natural bodies of water. 21016.8 requires GFI protection for any receptacle outside. Remainder of installation compliant. Recall when GFI protection installed

**Corrections:**

Sincerely,

Tom Cook  
Electrical Plan Reviewer/Inspector  
tcook@co.routt.co.us  
(970) 870-5339