



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Oct 02, 2023

Inspection Result: PASSED

Permit Number: PREL231278

Issuance Date: Sep 19, 2023

Property Address: 38625 ROLLINGHILLS LN, UNIT:A, ROUTT, CO 80487;

Applicant: Powder Horn Electric

Contractor: Powder Horn Electric P O Box 582 Hayden, Co 81639 (970) 819-9598

To construct: Make corrections to existing house and shop per inspection report

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: water heater corrected. final approved

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339