



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Oct 25, 2023

Inspection Result: PARTIAL PASS

Permit Number: PRAB230688

Issuance Date: Aug 04, 2023

Property Address: 29445 SCRUB OAK PATH, ROUTT, CO 80487;

Applicant: Ski Town Roofing, LLC

Contractor:

To construct: We will be adding a 40'x40' storage barn on our property. The building will be fabricated with Steel and sheet metal. The barn will have electricity ran to the building. No plumbing as this is a storage barn. Open Floor Plan, No walls or partitions.

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Foundation walls size to approved plans. All rebar installed is sized and spaced correctly. Will need to see pilasters again before pouring to see proper rebar clearance to forms. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us
(970) 870-5331