



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Oct 26, 2023

Inspection Result: PASSED

Permit Number: PRAB230688

Issuance Date: Aug 04, 2023

Property Address: 29445 SCRUB OAK PATH, ROUTT, CO 80487;

Applicant: Ski Town Roofing, LLC

Contractor:

To construct: We will be adding a 40'x40' storage barn on our property. The building will be fabricated with Steel and sheet metal. The barn will have electricity ran to the building. No plumbing as this is a storage barn. Open Floor Plan, No walls or partitions.

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Pilsater rebar clearances have been met. Approved, Ok to pour walls.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us
(970) 870-5331