



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Oct 16, 2023

Inspection Result: PASSED

Permit Number: PRAB230688

Issuance Date: Aug 04, 2023

Property Address: 29445 SCRUB OAK PATH, ROUTT, CO 80487;

Applicant: Ski Town Roofing, LLC

Contractor:

To construct: We will be adding a 40'x40' storage barn on our property. The building will be fabricated with Steel and sheet metal. The barn will have electricity ran to the building. No plumbing as this is a storage barn. Open Floor Plan, No walls or partitions.

On this day we have inspected your construction for **Footing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Footing steel is good, dowels onsite, Jacoby will add before casting concrete.

Corrections:

Sincerely,

A handwritten signature in black ink, appearing to read 'Ted Allen'.

Ted Allen
Plan Review Examiner/Assistant Building
Official
tallen@co.routt.co.us
(970) 870-5329