



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Oct 30, 2023

Inspection Result: PASSED

Permit Number: PRMH221652

Issuance Date: Nov 01, 2022

Property Address: 30535 MARSHALL RIDGE, ROUTT, CO 80487;

Applicant: Mountain Home Stove & Fireplace

Contractor: Mountain Home Stove & Fireplace P.O. BOX 775491 Steamboat Springs, CO 80477 (970) 879-7962 AMARON-FOLKESTAD CONSTRUCTION P.O. BOX 773103 STEAMBOAT SPGS, CO 80477 (970) 879-9598

To construct: gas fireplace

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Fireplace system complete and operational

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371