



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Nov 09, 2023

Inspection Result: PARTIAL PASS

Permit Number: PRAD210132

Issuance Date: Jul 20, 2023

Property Address: 27315 HOME RANCH RD, ROUTT, CO 80428;

Applicant: SNAKE RIVER CONSTRUCTION

Contractor: SNAKE RIVER CONSTRUCTION PO BOX 773504 Steamboat Springs, CO
80477 (970) 846-2301

To construct: Alteration and addition to existing lodge.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Garage trusses have been installed correctly with approved fixes for king posts and have hurricane clips installed. OK to install drywall on garage ceiling when above ceiling electrical work is inspected.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347