



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Nov 15, 2023

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRPF230984

**Issuance Date:** Sep 05, 2023

**Property Address:** 18195 STATE HIGHWAY 131, ROUTT, CO 80483;

**Applicant:** Elizabeth Herbert

**Contractor:** Amplify Architecture PO Box 774121 Steamboat Springs, CO 80477 (970) 879-7929

**To construct:** Set Modular on a crawl space foundation.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Post and beam center support exceeds plan, Passed

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us  
(970) 870-5371