



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Nov 28, 2023

Inspection Result: FAILED

Permit Number: PREL231001

Issuance Date: Aug 10, 2023

Property Address: 34620 COUNTRY GREEN RD, ROUTT, CO 80487;

Applicant: A-PEKS ELECTRIC

Contractor: A-PEKS ELECTRIC 300 Blackberry Ln steamboat, CO 80487 (970) 734-5050

To construct: New electric

On this day we have inspected your construction for **Electrical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Temp service not securely supported

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339