



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Dec 04, 2023

Inspection Result: FAILED

Permit Number: PRAB231069

Issuance Date: Sep 19, 2023

Property Address: 42020 COUNTY ROAD 80, ROUTT, CO 81639;

Applicant: ERE Squared LLC

Contractor: ERE Squared LLC 276 Harvest Dr Steamboat Springs, Co 80487 (970) 846-4516

To construct: New unconditioned Accessory Building, no utilities.

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: R15 spray foam is installed in walls and R49 in ceilings of smaller bay that is intended to be heated. As of now no plans are approved for adding heat to building. Move ahead at own risk.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347