



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Dec 04, 2023

Inspection Result: FAILED

Permit Number: PRAB231069

Issuance Date: Sep 19, 2023

Property Address: 42020 COUNTY ROAD 80, ROUTT, CO 81639;

Applicant: ERE Squared LLC

Contractor: ERE Squared LLC 276 Harvest Dr Steamboat Springs, Co 80487 (970) 846-4516

To construct: New unconditioned Accessory Building, no utilities.

On this day we have inspected your construction for **Foundation/Underslab Insulation** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: R15 foam board installed on exterior of the south long foundation wall. No approved plans for heat are approved, move ahead at own risk.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347