



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Dec 11, 2023

Inspection Result: PARTIAL PASS

Permit Number: PREL231696

Issuance Date: Dec 10, 2023

Property Address: 42020 COUNTY ROAD 80, ROUTT, CO 81639;

Applicant: Quality Electric Colorado

Contractor: Quality Electric Colorado 110 S. Kendall St Lakewood, CO 80226 (720) 251-1843

To construct: Electrical rough in and trim and generator hookup

On this day we have inspected your construction for **Electrical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Equipment ground number 6 copper or number four aluminum from electrical panel grounding system to main service disconnect required. Grounding electrode conductor from concrete in case the electrode to main service disconnect required number for copper or number two aluminum. Concrete in case electrode clamp will require access to be tightened at a later date. Vertical runs of MC cable require supports in intervals not exceeding 6 ft

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339