



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Dec 15, 2023

**Inspection Result:** PASSED

**Permit Number:** PRAB231069

**Issuance Date:** Sep 19, 2023

**Property Address:** 42020 COUNTY ROAD 80, ROUTT, CO 81639;

**Applicant:** ERE Squared LLC

**Contractor:** ERE Squared LLC 276 Harvest Dr Steamboat Springs, Co 80487 (970) 846-4516

**To construct:** New Partially Conditioned Building, Accessory Building used only portions of the year per approved Planning Dept SUP. See document called "ARCH Energy Code Compliance (STAMPED)" for energy code and only heated portion of this building approved.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** All spray foam now covered with intumescent paint. All final building and life safety items are completed to approved plans. Final approved.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347