



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Dec 19, 2023

Inspection Result: PASSED

Permit Number: PRAB220629

Issuance Date: Aug 03, 2022

Property Address: 25325 PARADISE VALLEY LN, ROUTT, CO 80467;

Applicant: Colette Burris

Contractor:

To construct: Detached Accessory Building originally built by former owners to be a barn, however its partially a barn and partially an office on one end. This permit application is being provided due to the fact that the former owners did not permit the building originally. Includes existing improvements in barn and barn office: electrical, plumbing, point of use hot water heater, kitchen sink, and shower. Additional work in barn and barn office: installation of hot water heater, toilet and bathroom in conjunction with applicable Onsite Wastewater Permit.

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Office only, 1 1/2" foam board and R-19 batts in walls with vapor barrier, Ceiling looks to be R-30 fiberglass. Barn is uninsulated

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371