



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Dec 19, 2023

Inspection Result: PASSED

Permit Number: PRMH231687

Issuance Date: Dec 06, 2023

Property Address: 55900 HANNAHS WAY, ROUTT, CO 80428;

Applicant: JDW INC

Contractor: JDW INC P.O. BOX 770562 STEAMBOAT SPGS, CO 80477

To construct: FURNACE Emergency install

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Replacement furnace has been installed and vented correctly with all clearances met and condensate treated. Final approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347