



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jan 25, 2024

Inspection Result: PARTIAL PASS

Permit Number: PREL231437

Issuance Date: Oct 10, 2023

Property Address: 18195 STATE HIGHWAY 131, ROUTT, CO 80483;

Applicant: STAGECOACH ELECTRIC, INC.

Contractor: STAGECOACH ELECTRIC, INC. P.O. BOX 775508 STEAMBOAT SPRINGS, CO 80477 (970) 846-3316

To construct: Branch main service to subpanel to modular house.

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial approval for final bathroom receptacles required GFI protection

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339