



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jan 26, 2024

Inspection Result: PASSED

Permit Number: PRRF231367

Issuance Date: Oct 05, 2023

Property Address: 54175 COUNTY ROAD 129, ROUTT, CO 80428;

Applicant: Revelation Roofing

Contractor: Revelation Roofing 2659 Jacob Cir Steamboat Springs, CO 80487 (972) 922-9919

To construct: We will remove 40sq of pro panel metal roofing and replace with 26ga Pro Panel metal. We will not be changing any colors of the roof. We will fully cover the roof with WIP 300 HT ice/water shield and replace all flashing with 26ga CMG metal.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Photo Inspection. WIP Ice and water shield installed over roof deck, laps appear correct. Roof fully finished with all new metal panels and flashing. Final approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347