



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Jan 31, 2024

**Inspection Result:** PASSED

**Permit Number:** PRGS231675

**Issuance Date:** Dec 01, 2023

**Property Address:** 27315 HOME RANCH RD, UNITD, ROUTT, CO 80428;

**Applicant:** Devin Jurgensen

**Contractor:** SNAKE RIVER CONSTRUCTION PO BOX 773504 Steamboat Springs, CO  
80477 (970) 846-2301

**To construct:** New construction, 3-1000 gallon underground tank sets  
37515 Home Ranch Rd. Steamboat Springs, CO. 80487

On this day we have inspected your construction for **Gas Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** 3- 1000 gallon underground tanks and gas lines with trace wire have been installed and bedded correctly. Pressure tests good at 20 psi for 15 minutes. Approved to backfill.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347