



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Feb 20, 2024

Inspection Result: PARTIAL PASS

Permit Number: PREL240088

Issuance Date: Feb 14, 2024

Property Address: 198 E LINCOLN AVE, HAYDEN, CO 81639;

Applicant: COONS CUSTOM ELECTRIC INC.

Contractor: COONS CUSTOM ELECTRIC INC. P.O. BOX 882379 STEAMBOAT SPGS,,
CO 80488 (970) 846-5609

To construct: We have added a sub panel in the rear area.

I'm likely out of town on Blues break.

The property owner Patrick Delaney can show the pipe and sub panel in question OR my employee Morgan Biggart will be able to be present if Patrick is unable

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial approval for final electrical. Use of extension cords at wine bar point of sale prohibited permanent receptacles required

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339