



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Apr 03, 2024

Inspection Result: PASSED

Permit Number: PRWD231723

Issuance Date: Dec 19, 2023

Property Address: 33790 SKY VALLEY DR, UNITA, ROUTT, CO 80487;

Applicant: RENEWAL BY ANDERSEN

Contractor: RENEWAL BY ANDERSEN 1401 W BAYAUD AVE DENVER, CO 80223
(303) 945-1519

To construct: Replacing 14 windows like for like. u factor will be .30 or better

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Windows trimmed and sealed.

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371