



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Apr 10, 2024

**Inspection Result:** PASSED

**Permit Number:** PRMH231087

**Issuance Date:** Aug 23, 2023

**Property Address:** 34620 COUNTRY GREEN RD, ROUTT, CO 80487;

**Applicant:** CROSS MOUNTAIN PLMB & HEAT

**Contractor:** CROSS MOUNTAIN PLMB & HEAT P.O. BOX 771905 STEAMBOAT SPGS,,  
CO 80477 (970) 819-4276

**To construct:** Radiant heat boiler system.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Heat tube and manifolds complete, staple up and in slab, one gauge 100 psi Gas lines complete. Boiler intake and exhaust installed

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us  
(970) 870-5371