



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Apr 10, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRAB230688

**Issuance Date:** Aug 04, 2023

**Property Address:** 29445 SCRUB OAK PATH, ROUTT, CO 80487;

**Applicant:** Ski Town Roofing, LLC

**Contractor:**

**To construct:** We will be adding a 40'x40' storage barn on our property. The building will be fabricated with Steel and sheet metal. The barn will have electricity ran to the building. No plumbing as this is a storage barn. Open Floor Plan, No walls or partitions.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** See corrections, all other steel framing and bracing has been done to approved plans.

## Corrections:

1. Need to get engineers approval for changing cable bracing and location of overhead doors
2. Submit welding certificate of person doing the welded connections for the building

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347