



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Apr 22, 2024

Inspection Result: PARTIAL PASS

Permit Number: PRMH240292

Issuance Date: Apr 16, 2024

Property Address: 34620 COUNTRY GREEN RD, ROUTT, CO 80487;

Applicant: JDW INC

Contractor: JSM BUILDERS Inc PO BOX 881773 STEAMBOAT SPGS, CO 80488

To construct: Installation of:

- (1) 12K Mitsubishi Ceiling Cassette
- (2) 18K Mitsubishi Ceiling Cassette
- (1) 48K Outdoor Unit
- (1) Kitchen Hood Vent
- (4) Exhaust Fans

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Mini split line set, holding 450 psi

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371