



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: May 03, 2024

Inspection Result: PARTIAL PASS

Permit Number: PRPL240394

Issuance Date: May 02, 2024

Property Address: 26105 COUNTY ROAD 37B, ROUTT, CO 81639;

Applicant: Peace Plumbing

Contractor: Peace Plumbing 420 E 57th Loveland, CO 80538

To construct: Plumbing for New Single Family Dwelling.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Underground DWV lines have been installed and bedded correctly per approved plans. Pressure test good at 7 psi for 15 minutes. Approved to cover.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347