



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** May 07, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRPF231763

**Issuance Date:** Apr 23, 2024

**Property Address:** 38700 MAIN ST, ROUTT, CO 80487;

**Applicant:** Ben Beall

**Contractor:** TO BE DETERMINED BEFORE PERMIT ISSUANCE <NO STREET ADDRESS> Diane Dwire 3500 DUCKELS CT. STEAMBOAT SPGS, CO 80487 (970) 879-6072 Duckels Construction Inc. 3500 DUCKELS CT. Steamboat Springs, 80487

**To construct:** Construction of Town of Milner wastewater treatment plant including site-built, below-ground tanks that also serve as the foundation for placement of factory-built, modular, containerized treatment facility on top of tanks.

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Foundation pad for water treatment tank has been formed to approved plans with all rebar sized and spaced correctly. Approved to pour.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347