



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** May 22, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRPL240498

**Issuance Date:** May 21, 2024

**Property Address:** 29775 DRY CREEK TRL, ROUTT, CO 80467;

**Applicant:** LFM MECHANICAL

**Contractor:** LFM MECHANICAL P.O. BOX 882331 STEAMBOAT SPRINGS, CO 80488  
(970) 819-5115

**To construct:** Pipe water lines in barn

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Water lines, underground, for new barn, below frost depth, ok to bury

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us  
(970) 870-5371