



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: May 23, 2024

Inspection Result: PASSED

Permit Number: PRPL240509

Issuance Date: May 22, 2024

Property Address: 27315 HOME RANCH RD, UNITA, ROUTT, CO 80428;

Applicant: ACTION MECHANICAL INC.

Contractor: ACTION MECHANICAL INC. P.O. BOX 698 CLARK, CO 80428 (970) 819-1174

To construct: complete plbg system

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: DWV and waterlines run to locations on approved plans. All pipes are properly supported and protected. DWV test is good at 6psi and waterlines are good at 60psi. Gas line installed to 15 locations and passed test of 15psi. Gas line properly supported and protected. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us
(970) 870-5331