



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: May 30, 2024

Inspection Result: PARTIAL PASS

Permit Number: PRAD210132

Issuance Date: Jul 20, 2023

Property Address: 27315 HOME RANCH RD, UNITA, ROUTT, CO 80428;

Applicant: SNAKE RIVER CONSTRUCTION

Contractor: SNAKE RIVER CONSTRUCTION PO BOX 773504 Steamboat Springs, CO
80477 (970) 846-2301

To construct: Alteration and addition to existing lodge.

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Entryway and south and kitchen and garage ceilings have R60 spray foam and batts. Partial approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347