



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** May 14, 2024

**Inspection Result:** NOT READY

**Permit Number:** PRAD210132

**Issuance Date:** Jul 20, 2023

**Property Address:** 27315 HOME RANCH RD, ROUTT, CO 80428;

**Applicant:** SNAKE RIVER CONSTRUCTION

**Contractor:** SNAKE RIVER CONSTRUCTION PO BOX 773504 Steamboat Springs, CO  
80477 (970) 846-2301

**To construct:** Alteration and addition to existing lodge.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

## Comments:

## Corrections:

- 1 1. Get engineers approval for (2)2x12 rafters instead of LVL in storage loft in "Hawks Nest" and fastening pattern
2. Get engineers approval for entryway rafters interlocked at ridge instead of 2x12 ridge beam and hangers

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347