



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jun 04, 2024

Inspection Result: PARTIAL PASS

Permit Number: PRPF231764

Issuance Date: May 15, 2024

Property Address: 22158 COUNTY ROAD 12, ROUTT, CO 80469;

Applicant: Ben Beall

Contractor: Diane Dwire 3500 DUCKELS CT. STEAMBOAT SPGS, CO 80487 (970) 879-6072
Nicholle Douglas 3500 Duckels Court Steamboat Springs, CO 80487 (970) 879-6072 Ext: 306
Duckels Construction Inc. 3500 DUCKELS CT. Steamboat Springs, 80487

To construct: Construction of Town of Phippsburg wastewater treatment plant including site-built, below-ground tanks that also serve as the foundation for placement of factory-built, modular, containerized treatment facility on top of tanks.
FOUNDATION ONLY PERMIT ISSUED ON 05/13/2024

On this day we have inspected your construction for **Footing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Per plan, #8 mats, #6 verticals, no spacing or lap issues, ok to pour

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371