



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Jun 11, 2024

**Inspection Result:** PASSED

**Permit Number:** PRAB231203

**Issuance Date:** Nov 06, 2023

**Property Address:** 29775 DRY CREEK TRL, ROUTT, CO 80467;

**Applicant:** MORTON BUILDINGS, INC

**Contractor:** MORTON BUILDINGS, INC 252 W. ADAMS ST. MORTON, IL 61550 (970) 281-2439

**To construct:** New Morton Barn/Garage

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Morton system piers, 18,24 and 48" drilled bores, 4' deep. Ok to pour.

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us  
(970) 870-5371