



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Jun 17, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRPF231764

**Issuance Date:** May 15, 2024

**Property Address:** 22158 COUNTY ROAD 12, ROUTT, CO 80469;

**Applicant:** Ben Beall

**Contractor:** Diane Dwire 3500 DUCKELS CT. STEAMBOAT SPGS, CO 80487 (970) 879-6072  
Nicholle Douglas 3500 Duckels Court Steamboat Springs, CO 80487 (970) 879-6072 Ext: 306  
Duckels Construction Inc. 3500 DUCKELS CT. Steamboat Springs, 80487

**To construct:** Construction of Town of Phippsburg wastewater treatment plant including site-built, below-ground tanks that also serve as the foundation for placement of factory-built, modular, containerized treatment facility on top of tanks.  
FOUNDATION ONLY PERMIT ISSUED ON 05/13/2024

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Walls, all #6, 9x12" double mats, pilasters for beams and #3 corner bracing per plan. No lap or spacing issues, ok to close up and pour

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us  
(970) 870-5371