



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jun 25, 2024

Inspection Result: FAILED

Permit Number: PREL240677

Issuance Date: Jun 24, 2024

Property Address: 32855 COUNTY ROAD 5, ROUTT, CO 80479;

Applicant: Yutzy Construction

Contractor:

To construct: Permit to get inspection for Perm Service turned back on.

On this day we have inspected your construction for **Electrical Perm Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Meter loop services no longer code compliant. Violations starting at the top include but are not limited to, neutral connector has no connection to electrical service, service conductors and feeders cannot be contained in same raceway, main service disconnect has no legible markings stating over current limits. Romex requires listed outdoor connectors, receptacle requires GFI protection. Overcurrent device assumed to be too large for \$120 volt receptacle, white branch circuit conductor attached to circuit breaker creates 240 volt circuit. Inspector recommends contacting electrical contractor to replace service. Any questions please call 970-870-5339

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339