



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Jun 25, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRPL240679

**Issuance Date:** Jun 24, 2024

**Property Address:** 23620 FRAYSHER LN, ROUTT, CO 80467;

**Applicant:** ELLSWORTH PLUMBING & SERVICE

**Contractor:** ELLSWORTH PLUMBING & SERVICE P.O. BOX 772238 Steamboat Springs, CO 80477 (970) 457-0813

**To construct:** All plumbing for new build

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** In slab drains, complete, garage and basement stacks both over 5 psi.

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us  
(970) 870-5371