



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jul 16, 2024

Inspection Result: PASSED

Permit Number: PRGS240777

Issuance Date: Jul 15, 2024

Property Address: 34620 COUNTRY GREEN RD, ROUTT, CO 80487;

Applicant: SCHRADER PROPANE LLC

Contractor: SCHRADER PROPANE LLC P.O. BOX 775450 STEAMBOAT SPGS, CO
80477 (970) 819-7363

To construct: UNDERGROUND TANK SET & EXTERIOR, UNDERGROUND GAS LINE
INSTALLATION

On this day we have inspected your construction for **Gas Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Per pictures
pressure held at 15 PSI, gas line was fed through existing conduit, new underground gas line installed.
Approved.

Corrections:

Sincerely,

A handwritten signature in black ink, appearing to read 'Heidi Spengler'.

Heidi Spengler
Sr Permit Tech
hspengler@co.routt.co.us
(970) 870-5332