



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jul 24, 2024

Inspection Result: PARTIAL PASS

Permit Number: PRSF240344

Issuance Date: May 09, 2024

Property Address: 23620 FRAYSHER LN, ROUTT, CO 80467;

Applicant: Dovetail Designs LLC

Contractor: Dovetail Designs LLC 23595 Youngs Creek Way, Unit B Oak Creek, CO 80467

To construct: New Single Family Dwelling
3 Bedroom, 3.5 Bathroom
3800 Ft² Finished, 833 Ft² Unfinished

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Basement slab 2" of foam board

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371