



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jul 24, 2024

Inspection Result: PARTIAL PASS

Permit Number: PRMH240830

Issuance Date: Jul 23, 2024

Property Address: 23620 FRAYSHER LN, ROUTT, CO 80467;

Applicant: ELLSWORTH PLUMBING & SERVICE

Contractor: ELLSWORTH PLUMBING & SERVICE P.O. BOX 772238 Steamboat Springs, CO 80477 (970) 457-0813

To construct: New boiler system

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Basement and garage heat tube complete, holding 100 psi on two gauges

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371