



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Jul 31, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRPL231086

**Issuance Date:** Aug 23, 2023

**Property Address:** 34620 COUNTRY GREEN RD, ROUTT, CO 80487;

**Applicant:** CROSS MOUNTAIN PLMB & HEAT

**Contractor:** CROSS MOUNTAIN PLMB & HEAT P.O. BOX 771905 STEAMBOAT SPGS,,  
CO 80477 (970) 819-4276

**To construct:** New construction DWV, water piping, gas piping, fixture set.

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** All work completed to scope of permit except condensate discharge from A/C in master bedroom needs to be connected under sink. All fixtures installed, sealed and operational.

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us  
(970) 870-5331