



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Aug 08, 2024

Inspection Result: PASSED

Permit Number: PRMH230831

Issuance Date: Jul 18, 2023

Property Address: 26730 COUNTY ROAD 14, ROUTT, CO 80467;

Applicant: SIMPLY RADIANT HEATING & Simply Solar Heat

Contractor: SIMPLY RADIANT HEATING & Simply Solar Heat PO Box 775733
Steamboat Springs, CO 80477 (970) 879-6555

To construct: Geo-Exchange with radiant floor heating and chilled water cooling

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Hydronic tubing installed into WarmBoard floor and run to manifolds. Tubing test ids good at 100psi. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us
(970) 870-5331