



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Aug 09, 2024

Inspection Result: PASSED

Permit Number: PRGS240937

Issuance Date: Aug 07, 2024

Property Address: 23620 FRAYSHER LN, ROUTT, CO 80467;

Applicant: SCHRADER PROPANE LLC

Contractor: SCHRADER PROPANE LLC P.O. BOX 775450 STEAMBOAT SPGS, CO
80477 (970) 819-7363

To construct: UNDERGROUND TANK SET & UNDERGROUND, EXTERIOR GAS LINE
INSTALLATION

On this day we have inspected your construction for **Gas Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Gas line complete, locate wire, holding 10 psi

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371