



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Aug 19, 2024

Inspection Result: PARTIAL PASS

Permit Number: PRMH240817

Issuance Date: Jul 22, 2024

Property Address: 26730 COUNTY ROAD 14, ROUTT, CO 80467;

Applicant: BUTTON-UP INC.

Contractor: BUTTON-UP INC. 31215 FALLEN FALCON TRL OAK CREEK, CO 80467-963 (970) 819-0464

To construct: (1) Installation of Mitsubishi Hyper heat pump system.

(2) Installation of ERV system

(3) Dryer vent

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Bath fans, dryer vent and mini split line sets installed, no issues

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371