



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Aug 27, 2024

Inspection Result: PASSED

Permit Number: PRGS241031

Issuance Date: Aug 21, 2024

Property Address: 26105 COUNTY ROAD 37B, ROUTT, CO 81639;

Applicant: Mountain West Propane

Contractor:

To construct: Install 2 UG 1000 gal tanks and new service line to residence

On this day we have inspected your construction for **Gas Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 2- 1000 gallon underground tanks and gas line is installed and bedded correctly with trace wire. Pressure test good at 25 psi for 15 minutes. Approved to backfill.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347