



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Aug 27, 2024

Inspection Result: PASSED

Permit Number: PRSF221403

Issuance Date: Apr 10, 2023

Property Address: 26730 COUNTY ROAD 14, ROUTT, CO 80467;

Applicant: SUSTAINABLE BUILDING SOLUTIONS

Contractor: SUSTAINABLE BUILDING SOLUTIONS P.O. BOX 770578 STEAMBOAT
SPGS., CO 80477 (970) 819-4311

To construct: New Single Family Home With Attached Garage at 26730 County Road 14.

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All exterior is combination of continuous foam board, core bond spray and batts/blown in. Ceilings to R-70, walls to R-40, cantilevers R-60. All window exceed energy code

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371